



Vaporless Manufacturing, Inc.
 Quality Petroleum Equipment
 Solutions for Over 20 Years

LDT- 890 Test Form & VMI Warranty Checklist

October 1st, 2006

Test Information

Date: _____ Test Company: _____

Telephone: _____ Contact: _____

Site I.D.: _____ Address: _____

City: _____ State: _____ Zip: _____

Type of Test Equipment: _____

Submersible Pump Identification

MFG: _____ Model No: _____ Serial No: _____

Leak Detector Identification

MFG: _____ Model No: _____ Serial No: _____

Replacement Leak Detector Identification

MFG: _____ Model No: _____ Serial No: _____

Line Conditions

1. Type of Pipe: _____ 2. Diameter of Pipe: _____ 3. Length of Pipe: _____
 4. Burial Depth of Leak Detector: _____ 5. Kind of Fuel: _____ 6. Date of Last Line Test: _____

Test Conditions

1. Operating Pump Pressure: _____ 2. Gallon per hour test rate: _____ @ 10 psi
 3. Static Line Pressure (Pump Off): _____ 4. Bleedback Test (Pump Off): _____ ml.
 5. Step-through time to full flow _____ seconds (0 psi. to full pump pressure, no leak)
 6. Leak detector stays in Leak Search Position with a 3 GPH leak - Yes: _____ PASS No: _____ FAIL
 7. Was the leak detector adjusted – Yes: _____ No: _____

(See Website - www.vaporless.com - Technical Bulletin 032805)

Symptoms

1. Won't find 3 GPH leak: _____ 2. Stays in Slow Flow: _____
 3. Other: _____

***** If This Unit Is Returned Under Warranty Please Complete The Following *****

Vaporless RGA#: _____ Return By (Company): _____

Telephone: _____ Contact: _____

Customer Control #: _____ Address: _____

City: _____ State: _____ Zip: _____